








ITEM 10	 OFF CIRCUIT WARNING CHANGER	 NO HOT WORKING TIME	TAP CHANGER WARNING LABEL	
ITEM 6	 - C.O.L. 15°C -			COLD COOLANT LEVEL
ITEM 2	 Supplied by Wilbert Davis & Co. Ltd. Tel. 0113 277 1768 Fax. 0113 277 1124 www.wilbertdavis.co.uk	LV WARNING LABEL		
ITEM 1	 DANGER HIGH VOLTAGE	HV WARNING LABEL		



15	2	DETACHABLE RADIATORS with AIR-RELEASE & DRAIN PLUG (520W x 1200C x 45 x 40P)
14	1	DRAIN VALVE (25NB) with MALE PLUG
13	4	JACKING PADS
12	4	TRANSFORMER LIFTING LUGS
11	1	RATING & DIAGRAM PLATE (SS)
10	1	OFF-CIRCUIT TAP SWITCH (6-Position & Padlockable)
9	2	THERMOMETER POCKET (3/4" BSP MALE THREAD)
8	1	OIL FILLING PIPE WITH FLANGED COVER
7	1	TOP COVER with LIFTING LUGS (x2)
6	1	OIL LEVEL GAUGE (with 15°) COLD OIL LEVEL MARK
5	1	SILICA GEL BREATHER TYPE R
4	2	EARTHING TERMINAL (FLAT TYPE suitable for M12 Bolt)
3	1	TRANSFORMER BASE (SKID TYPE) c/w HAULAGE HOLES & BRACING
1	1	HV CABLE BOX - 12kV, 3-POLE, HEAT-SHRINK INSULATION, (FACING-'E' BS:2562) SUITABLE FOR 1 x 3c CABLE - MAX. 185mm.sq
ITEM	QTY	DESCRIPTION

REVISION HISTORY					
REV	REV BY	VERIFIED	APPROVED	DESCRIPTION	

CURRENT REVISION	REVISION DESCRIPTION	
	ORIGINAL	
	REV. BY:	J. NOVO
	VERIFIED:	
	APPROVED:	

PROJECT
CUSTOMER
S.O. NUMBER
P.O. NUMBER
W.O. NUMBER

DRAWN BY:
J. NOVO
DATE:
03/05/2024
DRAWING NO

Wilson Power Solutions Ltd.
Westland Square, Leeds,
West Yorkshire LS11 5SS, United Kingdom
Tel: +44 (0) 113 271 7588
Fax: +44 (0) 113 277 5124

web: www.wilsonpowersolutions.co.uk email: info@wilsonpowersolutions.co.uk

WPS-E4-1500-AL-GA	SHEET 1 OF 1
-------------------	--------------

DEF02 DEV 0.25 NOV 14