








WILSON
T² ECOTRANS

TRANSFORMER WEIGHT & VOLUME		
CORE AND WINDING	kg	2670
TANK AND FITTING	kg	1100
COOLING LIQUID VOLUME	L	1070
COOLING LIQUID WEIGHT	kg	870
TOTAL TX WEIGHT	kg	4640


VIEW OF LV SIDE - CABLE CLEAT STUDS
CABLES MUST BE SUPPORTED IN ACCORDANCE WITH
CURRENT IET Wiring Regulations BS7671 & IEC 61914



4x M12 x 30 @ 140mm PITCH ~430mm FROM THE GROUND

ESSENTIAL LABELS

- ITEM 10 TAP CHANGER WARNING LABEL
- ITEM 6 COLD COOLANT LEVEL
- ITEM 2 LV WARNING LABEL
- ITEM 1 HV WARNING LABEL



1600kVA ELECTRICAL RATINGS					
No Load Voltage Ratio at Normal Tap	HV Tappings	Vector Group	Frequency	Full-Load Current at Normal Tap	
				HV Side	LV Side
11000 / 433V	+5.0 to -5.0% in 2.5% INCREMENTS	Dyn11	50Hz	83.978A	2133.396A
Design Impedance at Normal Tap	No Load Losses at rated Voltage & Frequency	Full Load Losses at rated Current & at 75°C Temp.	Temp. Rise above Ambient 40°C		
			in Oil by Therm.	in Wdg. by Res.	
5.5%	1080W	12000W	60°C	65°C	
GENERAL NOTES					
1 ALL DIMENSIONS ARE IN 'mm'.					
2 ALL DIMENSIONS/WEIGHTS ARE SUBJECT TO ± 10% TOLERANCE.					
3 ELECTRONIC SCALE - 1:1 (ONLY WRITTEN DIMENSIONS TO BE FOLLOWED).					
4 TOLERANCE ON IMPEDANCE PER IEC:60076.					
5 PAINT SHADE.: 632 AS PER BS:381C (SEMI GLOSS) TO ISO12944 - MIN C4H SPEC.					
6					
7					
8					
9					

15	4	DETACHABLE RADIATORS with AIR-RELEASE & DRAIN PLUG (520W x 1200C x 55 x 40P)
14	1	DRAIN VALVE (25NB) with MALE PLUG
13	4	JACKING PADS
12	1	RATING & DIAGRAM PLATE (SS)
11	4	TRANSFORMER LIFTING LUGS
10	1	OFF-CIRCUIT TAP SWITCH (5-Position & Padlockable)
9	2	THERMOMETER POCKET (3/4" BSP MALE THREAD)
8	1	OIL FILLING PIPE WITH FLANGED COVER
7	1	TOP COVER with LIFTING LUGS (x2)
6	1	OIL LEVEL GAUGE (with 15°) COLD OIL LEVEL MARK
5	1	ENVIRO GEL BREATHING TYPE R
4	2	EARTHING TERMINAL (FLAT TYPE suitable for M12 Bolt)
3	1	TRANSFORMER BASE (SKID TYPE) c/w HAULAGE HOLES & BRACING
2	1	LV CABLE BOX - 1.1kV, 4-POLE, AIR INSULATION, (FACING-'F', BS:2562) SUITABLE FOR 3 x 1c CABLES PER PHASE & N - MAX. 630mm.sq
1	1	HV CABLE BOX - 12kV, 3-POLE, HEAT-SHRINK INSULATION, (FACING-'E' BS:2562) SUITABLE FOR 1 x 3c CABLE - MAX. 185mm.sq
ITEM	QTY	DESCRIPTION

IF IN DOUBT - **ASK**. REMOVE ALL SHARP EDGES. **DO NOT** SCALE. DRAWING **NOT TO SCALE**

LAST DEFINITION				
REV	REV BY	VERIFIED	APPROVED	DESCRIPTION

REVISION DESCRIPTION		REV	PROJECT
ORIGINAL		00	CUSTOMER
			S.O. NUMBER
			P.O. NUMBER
			W.O. NUMBER
REV. BY: S. MALLETT		DATE: 25-JAN-2021	
VERIFIED:			
APPROVED:			

REVISION DESCRIPTION	REV	PROJECT

PROJECT	DRAWING TITLE
CUSTOMER	GENERAL ARRANGEMENT DRAWING FOR
S.O. NUMBER	1600kVA WILSON T2 ECOTRANS
P.O. NUMBER	11000/433V, 50Hz, Dyn11, ONAN/KNAN
W.O. NUMBER	AL WOUND DISTRIBUTION TRANSFORMER

PROJECT	DRAWING TITLE
CUSTOMER	GENERAL ARRANGEMENT DRAWING FOR
S.O. NUMBER	1600kVA WILSON T2 ECOTRANS
P.O. NUMBER	11000/433V, 50Hz, Dyn11, ONAN/KNAN
W.O. NUMBER	AL WOUND DISTRIBUTION TRANSFORMER

PARTS LIST			
Wilson Power Solutions Ltd.			
Westland Square, Leeds, West Yorkshire LS11 5SS, United Kingdom			
Tel: +44 (0) 113 271 7588 Fax: +44 (0) 113 277 5124			
web: www.wilsonpowersolutions.co.uk email: info@wilsonpowersolutions.co.uk			
DRAWN BY: S. MALLETT	DATE: 25/01/2021	DRG NO: WPS-T2-1600-AL-GA	